

## CONSTRUCTION CODES UPDATE PAGE

Matter in plain text is unchanged. Matter underlined is new. Matter ~~stricken through~~ is deleted.

Source: Local Law 51 of 2010, effective July 1, 2011.

## BUILDING CODE

*Insert between pages 610 and 611 of your bound volume.*

Amend item 2 of section 3307.6.5 to read as follows:

2. The underside of sidewalk sheds shall be lighted at all times either by ~~natural~~ daylight or ~~artificial~~ electric light. The level of illumination shall be ~~the equivalent of that produced by 200 watt, 3400 lumen minimum, standard incandescent lamps enclosed in vandal-proof fixtures and spaced 15 feet (4572 mm) apart and 8 feet (2438 mm) above the floor level~~ a minimum of 1 foot-candle (11 lux) measured at the level of the sidewalk walking surface. All lamps shall be enclosed in vandal-proof fixtures, have a minimum luminous efficacy of 45 lumens per watt or greater, and be rated to operate at temperatures of 5°F (-15°C) and higher. Artificial Electric lighting units shall be inspected ~~nightly~~ daily; and burned out or inoperative units shall be replaced or repaired immediately. Photosensors may be used to control electric lighting according to the amount of daylight available. All photosensors shall be equipped for fail-safe operation ensuring that if the sensor or control fails, the lamps will provide the lighting levels required by this section.